




# Anode Bag Requirements

Minimum Anode Protection Requirement for coated Metal Gas Piping in Average Soil:

Gas Piping Size					
Anode Size	½" to ¾"	1" to 1 ½"	2"	3"	4"
<b>3 lb. Anode</b>	45 ft.				
<b>5 lb. Anode</b>	74 ft.	42 ft.	34 ft.	23 ft.	
<b>9 lb. Anode</b>		76 ft.	61 ft.	41 ft.	32 ft.
<b>17 lb. Anode</b>			115 ft.	78 ft.	60 ft.



**\*\*Not to Scale**

**Anode Bags to be sized Per Chart Above.**

*Note to all Plumbers, Contractors, inspectors and interested parties; the Anode bag requirement was adopted with the adoption of the 1994 Codes and has been enforced since January 1, 1996.*